

**TAMIL NADU FIRE AND RESCUE SERVICE DEPARTMENT**  
**NO OBJECTION CERTIFICATE**

LICENSE NO. 22 /V/2025

Cuddalore Fire and Rescue  
Service Station, Cuddalore.

DATE : 16.06.2025

Sub : Fire and rescue service department – Cuddalore  
Fire and Rescue Service Station for purpose of  
No objection certificate – Reg.

Ref : (1) G.O. No.122. School Edu (2) Dept, Date: 14.09.2004.  
(2) G.O. No.123 School Edu (2) Dept, Date: 14.09.2004.  
(3) Date of Requisition letter from The Principal,  
Roots International School– 16.06.2025

Based on the Govt. order mentioned above and the requisition letter given by the Roots International School, run by Roots Educational Charitable Trust at Sabdhagiri Universal Township, Thiruvanthipuram, Cuddalore- 607 002, Tamil Nadu the building and premises comprises of G+1 owned by Roots International School/ Roots Educational Charitable Trust have complied with the fire prevention and fire safety requirements in accordance with rule of State Fire Service Rules, and verified on 16.06.2025 in the presence of Tmt.P.Sarala, Principal, and that the school is granted No objection certificate for a period of three year (from 16.06.2025 to 15.06.2028) subject to the conditions stated below.

The above premises inspected by Asst. District Officer Fire & Rescue Services, G.Arumugam on 16.06.2025

**CONDITIONS**

1. This License is valid for three year from the date of issue.
2. Four numbers of ABC 5 Kg Extinguisher per 200 Sq.m should be provided.
3. Fire Safety Systems should be maintained in good working condition.
4. Mock drill to be conducted periodically with the help of local fire and Rescue Service Station.
5. Any erection of permanent or temporary structure should be intimated to this department.
6. A trained Fire Service Person, preferably retired one should be appointed.
7. Further to limit the occupant load and to ensure better fire and life safety measures the following additional measures are insisted.
  - a) Building occupancy capacity should not be more than 4 people per Sq.m as per the National Building Code-2005.
  - b) The staircase treads and flooring shall be treated with rough finish (grooving) to avoid falling of children.
  - c) As per Para 6.3 of the BIS Standards IS 14435:1997 as the classrooms have only one entrance, the capacity of the class rooms shall have to be limited to 45 students.
  - d) Periodical maintenance and care should be taken to maintain all fire



**CORRESPONDENT**

**ROOTS INTERNATIONAL SCHOOL,  
SRI SABDHAGIRI UNIVERSAL TOWNSHIP,  
THIRUVANTHIPURAM, CUDDALORE-607 401**




**PRINCIPAL**

**ROOTS INTERNATIONAL SCHOOL,  
SRI SABDHAGIRI UNIVERSAL TOWNSHIP,  
THIRUVANTHIPURAM, CUDDALORE-607 401**

Scanned with ACE Scanner

- protection equipments.
- e) Mock drill has to be conducted at regular intervals in consultation with the Station Officer, Fire and Rescue Services, Cuddalore.
  - f) The classrooms should always be in the ground floor upto 3<sup>rd</sup> standards.
  - g) The classroom doors/ windows should be made of either non-combustible material or materials with high fire-resistance rating.
  - h) The classroom doors/ windows shall always open outwards.
  - i) The classroom doors/ windows shutters when opened should not obstruct movement along the exit or escape route.
  - j) A Class room shall have two entrances. One door with opening towards the teachers end and the other door on the other end of the class room with only a simple latch / tower bolt arrangement for locking from inside. This door shall not have any arrangement for locking from outside.
  - k) The school shall have proper Evacuation of Plan of action to rescue the children during any emergency in the school premises.
  - L) Miniature Circuit Breakers/Earth Leakage Circuit Breakers should be provided.
  - M) **All the floors should be provided Down comer with Hose Reel System.**

If there is any violation and deviation from the Govt. Rule and Act the License issued will stand cancelled.



*[Signature]*  
 Asst. District Officer,  
 Fire & Resque Services,  
 Cuddalore Station.

To:  
 The Principal,  
 Roots International School,  
 ( Roots Educational Charitable Trust ),  
 Sabdhagiri Universal Township,  
 Thiruvanthipuram, Cuddalore- 607 002.

*[Signature]*  
 CORRESPONDENT

**ROOTS INTERNATIONAL SCHOOL,  
 SRI SABDHAGIRI UNIVERSAL TOWNSHIP,  
 THIRUVANTHIPURAM, CUDDALORE-607 401**

*[Signature]*  
 PRINCIPAL

**ROOTS INTERNATIONAL SCHOOL,  
 SRI SABDHAGIRI UNIVERSAL TOWNSHIP,  
 THIRUVANTHIPURAM, CUDDALORE-607 401**